

CORPS OF ENGINEERS


U. S. ARMY

ROOM NAME & NUMBER LIST	
NO.	NAME
101	HALLWAY
102	HALLWAY
103	1 BED ROOM
104	BATH
105	1 BED ROOM
106	BATH
107	JANITOR'S CLOSET
108	4 BED WARD
109	4 BED WARD
110	HALLWAY
111	MECHANICAL
112	HALLWAY
113	DAY ROOM
114	OFFICE
115	HALLWAY
116	EQUIPMENT ROOM
117	HALLWAY
118	4 BED WARD
119	4 BED WARD
120	TUB ROOM
121	TOILET
122	STAFF TOILET
123	SOILED UTILITY
124	WORK ROOM
125	1 BED ROOM
126	BATH
127	1 BED ROOM
128	BATH
129	NURSE'S STATION
130	HALLWAY
132	HALLWAY

PLAN NOTES:


1. ALL WIRING SHOWN SHALL BE 1/2" CONDUIT WITH #12 AWG WIRE AS INDICATED UNLESS OTHERWISE NOTED. ALL WIRE INSULATION SHALL BE RATED 75°C UNLESS OTHERWISE NOTED.
2. ALL RECEPTACLES SHALL BE MOUNTED AT +18" UNLESS OTHERWISE NOTED.
3. SEE G SERIES DRAWINGS FOR ELECTRICAL SYMBOL SCHEDULES, ABBREVIATIONS AND GENERAL NOTES.
4. ALL CLOCK OUTLETS SHALL BE MOUNTED AT +7'-0".
5. REF FURNISHED WITH PREWIRED JUNCTION BOX AND DISCONNECT - SEE DETAIL ON XHPV SERIES SHEETS.
6. WEF FURNISHED WITH PREWIRED JUNCTION BOX AND DISCONNECT - SEE DETAIL ON XHPV SERIES SHEETS.
7. SEE DRAWING E7 FOR RECEPTACLE LOCATIONS AROUND EACH PATIENT BED.
8. EACH RECEPTACLE SHALL HAVE ONE #12 INSULATED GROUND CONDUCTOR PER CIRCUIT CONNECTING TO EQUIPMENT GROUND. CONDUIT SIZE SHALL BE AS REQUIRED TO NOT EXCEED NATIONAL ELECTRICAL CODE CONDUIT FILL REQUIREMENTS.

FLOOR TO CEILING 2 - COMPARTMENT CHANNEL POLE TO PROVIDE POWER AND COMMUNICATION SERVICE TO COUNTER PROVIDE 2-5 AMP RECEPTACLES IN THE POWER COMPARTMENT AND INSTALL #42



UNIT B POWER PLAN
1/4 INCH = 1 FOOT

FOR ENLARGED PLAN
SEE E9 & E10



KEY PLAN

1/4" = 1'-0" 4" 2" 0 4" 8"

Symbol	Description	Date	Approved
Revisions			
J. E. SHIRRE COMPANY ARCHITECT - ENGINEER DIVISION GREENVILLE, SOUTH CAROLINA		US ARMY ENGINEER DIVISION HUNTSVILLE CORPS OF ENGINEERS HUNTSVILLE, ALABAMA	
Site adapt A/E:		ARMY MOBILIZATION DESIGNS	
Dwn. by: WLS		Ckd. by: JML	
Reviewed by: WLS		Date: 14 MAY 84	
Approved by: RSB		Drawing code: M 510-10-F	
Sheet reference number: E-4		Design file no.: M086504	
Sheet 4 of 11		Rev.	